



## ELECTRICAL SAFETY

Gunstock Mountain Resort is coordinating efforts with the New Hampshire State Electrical Inspector to insure that all artist, exhibitor, sponsor and vendor structures pass New Hampshire requirements for electrical safety. Listed below is a check list that Gunstock Mountain Resort will use to determine electrical safety compliance. In the event of a code infraction, Gunstock Mountain Resort will prohibit the artist, exhibitor, sponsor, and/or vendor from assembly of their structure until the safety hazard(s) is/are properly corrected.

Gunstock Mountain Resort strongly recommends that prior to arrival each artist, exhibitor, sponsor and/or vendor have a licensed electrician inspect their equipment using the following Electrical Safety Checklist.

### ELECTRICAL SAFETY CHECKLIST

- All electrical wiring and equipment must pass a visual inspection for physical damage and irregularities.
- All electrical wiring must be securely fixed and properly installed. In cases where electrical wiring might be subject to physical damage, the wiring must be provided with mechanical protection.
- All electrical wiring must be protected from environmental conditions. In wet locations, only wires specifically coded for “wet conditions” are permitted. Additionally, all wire junctions must be free of dirt and/or debris.
- All exterior use electrical wiring extension cords must be classified for “extra hard usage” which must be printed and clearly visible on the cord.
- All interior use electrical wiring extension cords must be classified for “hard usage” which must be printed and clearly visible on the cord.
- All electrical wiring must pass a “continuity test” before tapping into any electrical supply. This test ensures that the neutral terminals are completely independent of the bonding connections. In the event of a fault, the bonding connection must only carry “fault current”.
- All lighting fixtures must be treated as sources of heat, and as a result, must be a safe distance from ignitable objects such as tent materials, canvas, banners, etc. Contact, or even close proximity, will be regarded as a potential fire hazard.
- All lighting fixtures must be positioned in safe locations such that if the luminaries were to accidentally break, the broken contents would not fall upon staff, patrons and/or product.
- All luminaries must be protected from accidental breakage by a suitable fixture or guarded lamp holder.

As the State of New Hampshire Department of Electrical Safety mandates these precautions, Gunstock Mountain Resort will make no exceptions; these preventative steps are meant to ensure the safety of everyone. Electrical safety is a matter of life and death; consequently Gunstock Mountain Resort will treat this mandate as such. Gunstock Mountain Resort appreciates the cooperation of all parties involved to help make our facility and event enjoyable for everyone!

All questions regarding this matter may be directed to J. Douglas Irving, Director of Operations or Phil Huckins, Building Services Manager. Please feel free to contact Doug at 603-293-4341 X 106 or [dirving@gunstock.com](mailto:dirving@gunstock.com); or Phil at 603-293-4341 X 217.

Thank you.